


PR: Kate Bernier

<b>NFIRS-1 Basic</b> 	<b>A City of Berkeley Fire Department</b> Fire Department	<b>05/19/2010</b> Date	<b>17:57:00</b> Time	<b>2010-004443</b> Incident Number	<b>00</b> Exposure									
	<b>B Street address</b> 2984 COLLEGE AVE Berkeley, CA 94704  Census Tract													
<b>C Incident Type</b> Smoke or odor removal		<b>E<sub>1</sub> Dates and Times</b> Alarm Time 05/19/2010 17:57:00 Time Out 05/19/2010 17:59:45 Arrival 05/19/2010 18:03:08 Controlled Cleared 05/19/2010 18:48:51		<b>E<sub>2</sub> Shift and Alarms</b>  <b>A</b> <b>3</b> Shift                      Alarm                      District                      Alarm Box										
<b>D Mutual Aid</b>  Their FDID    State    Incident				<b>E<sub>3</sub> Special Studies</b>										
<b>F Actions Taken</b> 1. Investigate 2. Refer to proper authority		<b>G<sub>1</sub> Resources</b> Apparatus    Personnel  Suppression EMS Other Personnel Not on Apparatus Total Personnel		<b>G<sub>2</sub> Estimated Dollar Losses</b> Losses Property                      \$0 Contents                      \$0 Pre Incident Value Property                      \$0 Contents                      \$0										
<b>H<sub>1</sub> Casualties</b> <table border="1"><thead><tr><th></th><th>Deaths</th><th>Injuries</th></tr></thead><tbody><tr><td>Fire Service</td><td>0</td><td>0</td></tr><tr><td>Civilian</td><td>0</td><td>0</td></tr></tbody></table>			Deaths	Injuries	Fire Service	0	0	Civilian	0	0	<b>H<sub>3</sub> Hazardous Materials Release</b>		<b>J Property Use</b> Food and beverage sales, grocery store	
	Deaths	Injuries												
Fire Service	0	0												
Civilian	0	0												
<b>H<sub>2</sub> Detector</b>		<b>I Mixed Property Use</b>												
<b>L Remarks</b> E3 responded as single company for "smoking meter" in a restaurant. Investigation revealed the newly installed PG&E smart meter in the kitchen was hot to touch and smoking, with a orange glow inside the meter housing. Power was immediately shut off to the meter. The meter was pulled from its housing, and a small portion of the wall above the meter was taken out to check for possible extension behind the wall where the wires exited the meter. Also investigated was the attic space; where the metal conduit, containing electrical wires entered. No extension was noted. PG&E contacted, BC2 noted due to business being shut down, and also Environmental Health was notified by dispatch due to a Dry Chem extinguisher was discharged by employees in the kitchen. A follow up email was sent to Manuel Ramirez of Enviro. Health about the discharged extinguisher in a commercial kitchen. Scene turned over to PG&E.														
<b>M Kevin M White</b> Officer in Charge  <b>Kevin M White</b> Member Making Report		<b>Apparatus Operator</b> Rank  <b>Apparatus Operator</b> Rank		<b>2243</b> Assignment  <b>2243</b> Assignment										
				<b>05/19/2010</b> Date  <b>05/19/2010</b> Date										

smart meter fire